



Office of Purchasing/Contract Management
3410 Taft Boulevard Wichita Falls, Texas 76308-2099

March 12, 2020

ADDENDUM ONE (1)

RE: RFP 735-20-4330 Steam Expansion Joints

TO WHOM IT MAY CONCERN,

The following questions had been submitted and received the following responses.

- Would you please tell me what the estimated cost range is for the "Expansion Steam Joints - Midwestern State University" project? **Response: Estimates are not available at this time, however, please be advised the need for bonds if the cost is over \$100K.**
- Are you able to confirm if "Traverse" is the overall length or axial movements? **Travers is the allowed contraction or expansion of the expansion joint . Not the overall length.**

The deadline for questions has now passed. No additional questions will be accepted at this time.

Regards,

Joseph J. Mrugalski Jr.
Purchasing/Contract Management